



An ISO 9001:2015 Company

Anjani Portland Cement Limited

(A Subsidiary of Chettinad Cement Corporation Pvt. Limited)

PPC Test Certificate

Ref.: APCL/QUAS/TEST/ W.No:26

Date of Despatch: 25.06.2025

QUAS/F - 26

Particulars	Test Result	Requirement as per IS 1489(Part-1) : 2015
CHEMICAL (As per IS: 4032-1985)		
<ul style="list-style-type: none">LOI (%)I.R. (%)	<p>3.22 30.68</p>	<p>5.0 Max. Max:$X+4\frac{(100-X)}{100}$ Min : 0.60 x X (Where x is the Declared of Fly ash)</p>
<ul style="list-style-type: none">SO₃ (%)MgO (%)Chloride (%)Declared percentage of Pozzolana (%)	<p>2.21 1.16 0.05 33.0</p>	<p>3.0 Max. 6.0 Max. 0.10 Max. Min-15%,Max-35%</p>
PHYSICAL (As per IS: 4031-1988)		
<ul style="list-style-type: none">NC (%)Fineness (M²/Kg)SOUNDNESS:Le-Chatlier (mm)Autoclave (%)SETTING TIME (Minutes)InitialFinalCOMPRESSIVE STRENGTH (M Pa)3 Days7 Days28 Days	<p>32.4 352 01 0.016 150 250 23.5 33.6 U.T</p>	<p>300 Min. 10 Max. 0.8 Max. 30 Min. 600 Max. 16 Min. 22 Min. 33 Min.</p>

Certified that the cement complies
With IS 1489 (Part-1) : 2015

G.M (QUAS & Ope.)

Unit Head

Works : Anjanipuram, Gudimalkapuram(P), Chinthalapalem(V&M), Suryapeta (Dist), Telangana State – 508246
Head Office : # 6-3-553, Quena Square – 4th floor ,E3 & E4 ,Erramanzil , Somajiguda, , Hyderabad -500 082,Telangana,INDIA.