



An ISO 9001:2015 Company

Anjani Portland Cement Limited

(A Subsidiary of Chettinad Cement Corporation Pvt. Limited)

PPC Test Certificate

Ref.: APCL/QUAS/TEST/ W.No:33

Date of Despatch: 13.08.2025

QUAS/F - 26

Particulars	Test Result	Requirement as per IS 1489(Part-1) : 2015
CHEMICAL (As per IS: 4032-1985)		
<ul style="list-style-type: none">LOI (%)I.R. (%)	3.26 31.42	5.0 Max. $\text{Max: } X + 4 \frac{(100 - X)}{100}$ Min : 0.60 x X (Where x is the Declared of Fly ash)
<ul style="list-style-type: none">SO₃ (%)MgO (%)Chloride (%)Declared percentage of Pozzolana (%)	2.21 1.16 0.04 33.0	3.0 Max. 6.0 Max. 0.10 Max. Min-15%,Max-35%
PHYSICAL (As per IS: 4031-1988)		
<ul style="list-style-type: none">NC (%)Fineness (M²/Kg)	31.8 359	300 Min.
SOUNDNESS: <ul style="list-style-type: none">Le-Chatlier (mm)Autoclave (%)	01 0.012	10 Max. 0.8 Max.
SETTING TIME (Minutes) <ul style="list-style-type: none">InitialFinal	150 250	30 Min. 600 Max.
COMPRESSIVE STRENGTH (M Pa) <ul style="list-style-type: none">3 Days7 Days28 Days	24.0 34.3 46.3	16 Min. 22 Min. 33 Min.

Certified that the cement complies
With IS 1489 (Part-1) : 2015

G.M (QUAS & Ope.)

Unit Head

Works : Anjanipuram, Gudimalkapuram(P), Chinthalapalem(V&M), Suryapeta (Dist), Telangana State – 508246
Head Office : # 6-3-553, Quena Square – 4th floor ,E3 & E4 ,Erramanzil , Somajiguda, , Hyderabad -500 082,Telangana,INDIA.